



Certificate No. 01-016467/0112998

TYPE APPROVAL CERTIFICATE

This is to certify that this product complies with the Rules for the classification of ships, Part 1 - General requirements, Chapter 3 - Type approval of products.

TYPE AND DESCRIPTION OF PRODUCT:

PORTABLE POWDER FIRE EXTINGUISHER, Capacity 6 kg
Type PG6-HK ABC K25

MANUFACTURER:

ANAF FIRE PROTECTION S.p.A.

VIA DEL COMMERCIO No. 4

27020 TORRE D'ISOLA (PV)

ITALY

THE PRODUCT MEETS FOLLOWING RULES/REGULATIONS:

Rules for the classification of ships, Part 17-Fire Protection; International Convention for the Safety of Life at Sea SOLAS 1974, as amended; IMO Resolution A.951(23).

FURTHER DETAILS OF THE PRODUCT AND CONDITIONS FOR CERTIFICATION ARE GIVEN OVERLEAF.

APPROVAL IS VALID UNTIL: **2028-05-15**

Place and date: Split, 2024-05-16

Seal

Marinko Popović, dipl.ing.

NOTE: This certificate is not valid for equipment, the design or manufacture of which has been varied or modified from the specimen tested. The manufacturer should notify Croatian Register of Shipping of any modification or changes to the product in order to obtain a valid certificate.

DETAILED PRODUCT DESCRIPTION:

Portable powder fire extinguisher with CO₂ internal cylinder, Type PG6-HK ABC K25

Cylinder material: steel DD12 EN 10111

Cylinder dimensions (external diameter/height): 160/410 mm

Cylinder capacity: 7,1 l

Valve body material: brass

Type and extinguishing agent quantity: Powder FUREX ABC 50, 6 kg

Operating temperature range: - 30°C to + 60°C

Fire rating according to EN 3-7: 34A - 233B - C

APPLICATION / LIMITATIONS:

Extinguishing of class A, B and C fires on ships.

TYPE APPROVAL DOCUMENTATION:

Test report No. 3650-2005 dated 11.10.2005. issued by Istituto Masini S.r.l.

Drawings attached to the Test report:

no. 13167 dated 11.11.2004., no. 27610 dated 07.01.2003., no 20040 dated 02.07.2003., no. 21713 dated 08.05.2003., no. 20645 dated 28.04.2005., no. 20130 dated 02.07.2003., no. 20728 dated 01.07.2003., no. 20052 dated 28.04.2005. and no. 20098 dated 01.07.2003.

MARKING OF PRODUCT:

Each fire extinguisher shall be marked with: manufacturer's name, type of product and date of manufacture (month and year).

CONDITIONS FOR CERTIFICATION:

-