



Potvrda br. 02-004046/025846
Certificate No.

POTVRDA O TIPNOM ODOBRENJU TYPE APPROVAL CERTIFICATE

Potvrđuje se da ovaj proizvod udovoljava Pravilima za klasifikaciju brodova, Dio 1. - Opći propisi, Odjeljak 3. - Tipno odobrenje proizvoda.
This is to certify that this product complies with the Rules for the classification of ships, Part 1 - General requirements, Chapter 3 - Type approval of products.

TIP I OPIS PROIZVODA:
TYPE AND DESCRIPTION OF PRODUCT:

RASPRŠIVAČ
SPRAYING NOZZLE

Tip
Type

K 57

PROIZVOĐAČ:
MANUFACTURER:

PASTOR INŽENJERING d.d.
10437 Rakitje, Novačka 2
HRVATSKA - CROATIA

PROIZVOD UDOVOLJAVA SLIJEDEĆIM PRAVILIMA/PROPISIMA:
THE PRODUCT MEETS FOLLOWING RULES/REGULATIONS:

HRB: Pravila za klasifikaciju brodova, Dio 17. – Protupožarna zaštita.

CRS: Rules for the classification of ships, Part 17. – Fire protection.

Međunarodna Konvencija o sigurnosti života na moru SOLAS 1974, uz izmjene, i FSS kodeks, uz izmjene.

International Convention for the Safety of Life at Sea SOLAS 1974, as amended, and FSS Code, as amended.

DETALJI O PROIZVODU I UVJETIMA CERTIFIKACIJE DANI SU NA POLEĐINI.
FURTHER DETAILS OF THE PRODUCT AND CONDITIONS FOR CERTIFICATION ARE GIVEN OVERLEAF.

ODOBRENJE VRLJEDI DO: **2027-05-10**
APPROVAL IS VALID UNTIL:

Mjesto i datum: Split, 2023-05-10
Place and date:

M.P. _____
(Seal)

Marinko Popović, dip.ing.

NAPOMENA: Ova potvrda nije valjana ako se proizvod ili način njegove proizvodnje promijenio u odnosu na tipno ispitani proizvod. Proizvođač treba obavijestiti Hrvatski registar brodova o bilo kojoj izmjeni na proizvodu kako bi ishodio valjanu potvrdu.

NOTE: This certificate is not valid for equipment, the design or manufacture of which has been varied or modified from the specimen tested. The manufacturer should notify Croatian Register of Shipping of any modification or changes to the product in order to obtain a valid certificate.

PODROBNJI OPIS PROIZVODA:
DETAILED PRODUCT DESCRIPTION:

Mlaznica u sustavu raspršivanja vodom
Water spraying system nozzle

(provrt Ø 9 mm; spoj R 1/2")
(bore Ø 9 mm; conn. R 1/2")

PODRUČJE PRIMJENE / POSEBNI GRANIČNI UVJETI:
APPLICATION / LIMITATIONS:

Gašenje požara na brodovima, u sustavima raspršivanja vode.
Fire extinguishing on ships, in water spraying systems.

Protok vode: 41,5 ÷ 144 (l/min) pri tlaku 0,58 ÷ 6,4 (bar)
Water flow: at pressure of

DOKUMENTACIJA ZA TIPNO ODOBRENJE:
TYPE APPROVAL DOCUMENTATION:

Nacrt broj: SP 403.012
Drawing No.: SP 422.012
SP 400.010
SP 400.011
SP 400.012
SP 013.001K
SP 013.003K

Izvešće o ispitivanju br. 9/98 (FSB ZAGREB)
Test Report No.

Vidi pismo br. 507/TS/DP/020887 datirano 2000-03-23
See letter No. dated

OZNAČAVANJE PROIZVODA:
MARKING OF PRODUCT:

-

UVJETI ZA CERTIFIKACIJU:
CONDITIONS FOR CERTIFICATION:

-